



Building and Safety Division • Public Information

County of Ventura • Resource Management Agency • http://www.ventura.org/rma/build_safe

Main Office • 800 S. Victoria Ave, Ventura, CA. 93009 • 805 654-2771

East County Office • 3855-F Alamo St., 2nd Fl. #2091A, Simi Valley, CA. 93065 • 805 582-8064

Ventura County Mandatory Non-Residential Green Building Features and Measures

Instructions: Fill-in all of the spaces in the “Method of Compliance” column. Specify how compliance is achieved (i.e. proposed products or design) and specify the sheet number of the plans where compliance is shown. The “Verification” columns indicate when verification will occur, whether during plan review, inspection, or both. If documentation is checked, documentation showing compliance is to be provided to the Building Inspector prior to final inspection approval. If any item does not apply, specify the reason it does not apply.

SITE DEVELOPMENT	Method of Compliance	Verification		
		Plan Review	Inspector	Documentation
5.106.1 Storm water pollution prevention plan. For projects of one acre or less, develop a Storm Water Pollution Prevention Plan (SWPPP) that has been designed, specific to its site, conforming to the State Storm water NPDES Construction Permit or local ordinance, whichever is stricter, as is required for projects over one acre. The plan should cover prevention of soil loss by storm water run-off and/or wind erosion, of sedimentation, and/or of dust/particulate matter air pollution.		<input checked="" type="checkbox"/>		
5.106.4 Bicycle parking and changing rooms. Comply with Sections 5.106.4.1 and 5.106.4.2; or meet local ordinance, whichever is stricter.		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
5.106.4.1 Short-term bicycle parking. If the project is anticipated to generate visitor traffic, provide permanently anchored bicycle racks within 200 feet of the visitors' entrance, readily visible to passers-by, for 5% of visitor motorized vehicle parking capacity, with a minimum of one two-bike capacity rack.		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
5.106.4.2 Long-term bicycle parking. For buildings with over 10 tenant-occupants, provide secure bicycle parking for 5% of tenant-occupied motorized vehicle parking capacity, with a minimum of one space.		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
5.106.5.2 Designated parking. Provide designated parking for any combination of low-emitting, fuel-efficient, and car-pool/van pool vehicles as shown in Table 5.106.6.2.		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	

DIVISION OF BUILDING AND SAFETY COUNTY OF VENTURA BUILDING OFFICIAL _____ <i>Jim MacDonald, CBO</i>	B & S STD	B-58 Page 1 - 12
	Revised	Jan. 2011

SITE DEVELOPMENT	Method of Compliance	Verification		
		Plan Review	Inspector	Documentation
<p>5.106.8 Light pollution reduction. Comply with lighting power requirements in the California Energy Code and design interior and exterior lighting such that zero direct-beam illumination leaves the building site. Meet or exceed exterior light levels and uniformity ratios for lighting zones 1-4 as defined in Chapter 10 of the California Administrative Code, using the following strategies:</p>		<input checked="" type="checkbox"/>		
1. Shield all exterior luminaires or use cutoff luminaires.		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
2. Contain interior lighting within each source.		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
3. Allow no more than .01 horizontal Foot Candle 15 ft. beyond the site.		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
4. Contain all exterior lighting within property boundaries.		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
Exception: See Part 2, Chapter 12, Section 1205.6 for campus lighting requirements for parking facilities and walkways.		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
<p>5.106.10 Grading and Paving. The site shall be planned and developed to keep surface water away from buildings. Construction plans shall indicate how site grading or a drainage system will manage all surface water flows.</p>		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
ENERGY EFFICIENCY				
PERFORMANCE REQUIREMENTS				
<p>5.201.1 Scope The California Energy Commission will continue to adopt mandatory building standards.</p>		<input checked="" type="checkbox"/>		
WATER EFFICIENCY AND CONSERVATION				
INDOOR WATER USE				
<p>5.303.1 Meters. Separate meters shall be installed for the uses described in Sections 503.1.1 through 503.1.3. 5.303.1.1 Buildings in excess of 50,000 square feet. Separate submeters shall be installed as follows: See next page</p>			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
1. For each individual leased, rented, or other tenant space within the building projected to consume more than 100 gal/day.			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>

WATER EFFICIENCY AND CONSERVATION	Method of Compliance	Verification		
		Plan Review	Inspector	Documentation
INDOOR WATER USE				
2. For spaces used for laundry or cleaners, restaurant or food service, medical or dental office, laboratory, or beauty salon or barber shop projected to consume more than 100 gal/day.			<input checked="" type="checkbox"/>	
5.303.1.2 Excess consumption. Any building within a project or space within a building that is projected to consume more than 1,000 gal/day.		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
5.303.2 20% Savings. A schedule of plumbing fixtures and fixture fittings that will reduce the overall use of potable water within the building by 20% shall be provided. (Calculate savings by Water Use Worksheets.)		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
5.303.2.1 Multiple showerheads serving one shower. When single shower fixtures are served by more than one showerhead, the combined flow rate of all the showerheads shall not exceed the maximum flow rates specified in the 20% reduction column contained in Table 5.303.2.3 or the shower shall be designed to only allow one showerhead to be in operation at a time.		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
5.303.4 Wastewater reduction. Each building shall reduce the generation of wastewater by one of the following methods:		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
1. The installation of water-conserving fixtures or		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
2. Utilizing non-potable water systems		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
5.303.6 Plumbing Fixtures and Fittings. Plumbing fixtures (water closets and urinals) and fittings (faucets and showerheads) shall comply with the requirements listed for each type in Items listed in Table 5.303.6.		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
1. Water closets (toilets) – flushometer type		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
2. Water closets (toilets) – tank type		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
3. Urinals		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
4. Public lavatory faucets		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	

WATER EFFICIENCY AND CONSERVATION	Method of Compliance	Verification		
		Plan Review	Inspector	Documentation
INDOOR WATER USE				
5. Public metering self-closing faucets		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
6. Residential bathroom lavatory sink faucets		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
7. Residential kitchen faucets		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
8. Residential shower heads		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
9. Single shower fixtures served by more than one showerhead		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
OUTDOOR WATER USE				
5.304.1 Water budget. A water budget shall be developed for landscape irrigation use.		<input checked="" type="checkbox"/>		
5.304.2 Outdoor potable water use. For new water service, separate meters or submeters shall be installed for indoor and outdoor potable water use for landscaped areas between 1000 square feet and 5000 square feet		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
5.304.3 Irrigation design. In new nonresidential projects with between 1000 and 2500 square feet of landscaped area (the level at which the MLO applies), install irrigation controllers and sensors which include the following criteria, and meet manufacturer's recommendations. 5.304.3.1 Irrigation controllers. Automatic irrigation system controllers installed at the time of final inspection shall comply with the following: See next page		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
1. Controllers shall be weather- or soil moisture-based controllers that automatically adjust irrigation in response to changes in plants' needs as weather conditions change.		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
2. Weather-based controllers without integral rain sensors or communication systems that account for local rainfall shall have a separate wired or wireless rain sensor which connects or communicates with the controller(s). Soil moisture-based controllers are not required to have rain sensor input.		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	


WEATHER RESISTANCE AND MOISTURE MANAGEMENT	Method of Compliance	Verification		
		Plan Review	Inspector	Documentation
5.407.1 Weather protection. Provide a weather-resistant exterior wall and foundation envelope as required by California Building Code Section 1403.2 and California Energy Code Section 150, manufacturer's installation instructions, or local ordinance, whichever is more stringent.		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
5.407.2 Moisture control. Employ moisture control measures by the following methods;				
5.407.2.1 Sprinklers. Prevent irrigation spray on structures.			<input checked="" type="checkbox"/>	
5.407.2.2 Entries and openings. Design exterior entries and openings to prevent water intrusion into buildings.		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
CONSTRUCTION WASTE REDUCTION, DISPOSAL AND RECYCLING				
5.408.1 Construction waste diversion. Establish a construction waste management plan or meet local ordinance, whichever is more stringent.	Comply with Ventura county Ordinance 4357 and Complete Reporting Forms			<input checked="" type="checkbox"/>
5.408.2 Construction waste management plan. Submit plan per this section to enforcement authority.	Comply with Ventura county Ordinance 4357 and Complete Reporting Forms			<input checked="" type="checkbox"/>
5.408.2.1 Documentation. Provide documentation of the waste management plan that meets the requirements listed in section 5.408.2 items 1 thru 4, the enforcement authority.	Comply with Ventura county Ordinance 4357 and Complete Reporting Forms			<input checked="" type="checkbox"/>
5.408.2.2 Isolated jobsites. The enforcing agency may make exceptions to the requirements of this section when jobsites are located in areas beyond the haul boundaries of the diversion facility.	Comply with Ventura county Ordinance 4357 and Complete Reporting Forms			<input checked="" type="checkbox"/>
5.408.3 Construction waste. Recycle and/or salvage for reuse a minimum of 50% of non-hazardous construction and demolition debris or meet local ordinance, whichever is more stringent.	Comply with Ventura county Ordinance 4357 and Complete Reporting Forms			<input checked="" type="checkbox"/>
Exceptions: 1. Excavated soil and land-clearing debris. 2. Alternate waste reduction methods developed by working with local agencies if diversion or recycle facilities capable of compliance with this item do not exist.	Comply with Ventura county Ordinance 4357 and Complete Reporting Forms			<input checked="" type="checkbox"/>

CONSTRUCTION WASTE REDUCTION, DISPOSAL AND RECYCLING	Method of Compliance	Verification		
		Plan Review	Inspector	Documentation
A5.408.3.1 Enhanced construction waste reduction. Divert to recycle or salvage non-hazardous construction and demolition debris generated at the site in compliance with one of the following: Tier 1. At least a 65% reduction. Tier 2. At least an 80% reduction.				<input checked="" type="checkbox"/>
A5.408.3.1.1 Verification of compliance. A copy of the completed waste management report shall be provided.	Comply with Ventura county Ordinance 4357 and Complete Reporting Forms			<input checked="" type="checkbox"/>
Exceptions: 1. Excavated soil and land-clearing debris. 2. Alternate waste reduction methods developed by working with local agencies if diversion or recycle facilities capable of compliance with this item do not exist.	Comply with Ventura county Ordinance 4357 and Complete Reporting Forms			<input checked="" type="checkbox"/>
5.408.4 Excavated soil and land clearing debris. 100% of trees, stumps, rocks and associated vegetation and soils resulting primarily from land clearing shall be reused or recycled.	Comply with Ventura county Ordinance 4357 and Complete Reporting Forms			<input checked="" type="checkbox"/>
BUILDING MAINTENANCE AND OPERATION				
5.410.1 Recycling by occupants. Provide readily accessible areas that serve the entire building and are identified for the depositing, storage, and collection of non-hazardous materials for recycling.1		<input checked="" type="checkbox"/>		
5.410.2 Commissioning. For new buildings 10,000 square feet and over, building commissioning for all building systems covered by T24, Part 6, process systems, and renewable energy systems shall be included in the design and construction processes of the building project. Commissioning requirements shall include items listed in 5.410.2.		<input checked="" type="checkbox"/>		
5.410.2.1 Owner's Project Requirements (OPR). Documented before the design phase of the project begins the OPR shall include items listed in 5.410.4.		<input checked="" type="checkbox"/>		
5.410.2.2 Basis of Design (BOD). A written explanation of how the design of the building systems meets the OPR shall be completed at the design phase of the building project and updated periodically to cover the systems listed in 5.410.2.2.		<input checked="" type="checkbox"/>		

BUILDING MAINTENANCE AND OPERATION	Method of Compliance	Verification		
		Plan Review	Inspector	Documentation
5.410.2.3 Commissioning plan. A commissioning plan describing how the project will be commissioned shall be started during the design phase of the building project and shall include items listed in 5.410.2.3.		<input checked="" type="checkbox"/>		
5.410.2.4 Functional performance testing shall demonstrate the correct installation and operation of each component, system, and system-to-system interface in accordance with the approved plans and specifications.			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
5.410.2.5 Documentation and training. A Systems Manual and Systems Operations Training are required.			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
5.410.2.5.1 Systems manual. The Systems Manual shall be delivered to the building owner or representative and facilities operator and shall include the items listed in 5.410.2.5.1.			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
5.410.2.5.2 Systems operations training. The training of the appropriate maintenance staff for each equipment type and/or system shall include items listed in 5.410.2.5.2.			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
5.410.2.6 Commissioning report. A complete report of commissioning process activities undertaken through the design, construction and reporting recommendations for post-construction phases of the building project shall be completed and provided to the owner or representative.			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
5.410.4 Testing and adjusting. Testing and adjusting of systems shall be required for buildings less than 10,000 square feet.			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
5.410.4.2 Systems. Develop a written plan of procedures for testing and adjusting systems. Systems to be included for testing and adjusting shall include, as applicable to the project, the systems listed in 5.410.3.2.			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
5.410.4.3 Procedures. Perform testing and adjusting procedures in accordance with industry best practices and applicable national standards on each system.			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>

REQUIREMENTS	Method of Compliance	Verification		
		Plan Review	Inspector	Documentation
BUILDING MAINTENANCE AND OPERATION				
5.410.4.3.1 HVAC balancing. Before a new space-conditioning system serving a building or space is operated for normal use, the system should be balanced in accordance with the procedures defined by national standards listed in 5.410.3.3.1.			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
5.410.4.4 Reporting. After completion of testing, adjusting and balancing, provide a final report of testing signed by the individual responsible for performing these services.			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
5.410.4.5 Operation and maintenance manual. Provide the building owner with detailed operating and maintenance instructions and copies of guaranties/warranties for each system prior to final inspection.			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
5.410.4.5.1 Inspections and reports. Include a copy of all inspection verifications and reports required by the enforcing agency.			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
ENVIRONMENTAL QUALITY				
FIREPLACES				
5.503.1. Install only a direct-vent sealed-combustion gas or sealed wood-burning fireplace, or a sealed woodstove, and refer to residential requirements in the California Energy Code, Title 24, Part 6, Subchapter 7, Section 150.			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
5.503.1.1 Woodstoves. Woodstoves shall comply with US EPA Phase II emission limits.			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
5.504.3 Covering of duct openings and protection of mechanical equipment during construction. At the time of rough installation, or during storage on the construction site and until final startup of the heating and cooling equipment, all duct and other related air distribution component openings shall be covered with tape, plastic, sheetmetal or other methods acceptable to the enforcing agency to reduce the amount of dust or debris which may collect in the system.				<input checked="" type="checkbox"/>
5.504.4 Finish material pollutant control. Finish materials shall comply with Sections 5.504.4.1 through 5.504.4.4.				<input checked="" type="checkbox"/>

ENVIRONMENTAL QUALITY	Method of Compliance	Verification		
		Plan Review	Inspector	Documentation
FIREPLACES				
<p>5.504.4.1 Adhesives, sealants, caulks. Adhesives and sealants used on the project shall meet the requirements of the following standards.</p> <p>1. Adhesives, adhesive bonding primers, adhesive primers, sealants, sealant primers, and caulks shall comply with local or regional air pollution control or air quality management district rules where applicable, or SCAQMD Rule 1168 VOC limits, as shown in Tables 5.504.4.1 and 5.504.4.2.</p>			<input checked="" type="checkbox"/>	
<p>2. Aerosol adhesives, and smaller unit sizes of adhesives, and sealant or caulking compounds (in units of product, less packaging, which do not weigh more than one pound and do not consist of more than 16 fluid ounces) shall comply with statewide VOC standards and other requirements, including prohibitions on use of certain toxic compounds, of California Code of Regulations, Title 17, commencing with Section 94507.</p>			<input checked="" type="checkbox"/>	
<p>5.504.4.3 Paints and coatings. Architectural paints and coatings shall comply with Table 5.504.4.3 unless more stringent local limits apply.</p>			<input checked="" type="checkbox"/>	
<p>5.504.4.3.1 Aerosol Paints and Coatings. Aerosol paints and coatings shall meet the Product-Weighted MIR Limits for ROC in section 94522(a)(3) and other requirements, including prohibitions on use of certain toxic compounds and ozone depleting substances (CCR, Title 17, Section 94520 et seq).</p>			<input checked="" type="checkbox"/>	
<p>5.504.4.3.2 Verification. Verification of compliance with this section shall be provided at the request of the enforcing agency.</p>			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
<p>5.504.4.4 Carpet systems. All carpet installed in the building interior shall meet the testing and product requirements of one of the standards listed in 5.504.4.4.</p>			<input checked="" type="checkbox"/>	
<p>5.504.4.4.1 Carpet cushion. All carpet cushion installed in the building interior shall meet the requirements of the Carpet and Rug Institute Green Label program.</p>			<input checked="" type="checkbox"/>	

ENVIRONMENTAL QUALITY	Method of Compliance	Verification		
		Plan Review	Inspector	Documentation
FIREPLACES				
5.504.4.4.2 Carpet adhesive. All carpet adhesive shall meet the requirements of Table 804.4.1.			<input checked="" type="checkbox"/>	
5.504.4.5 Composite wood products. Hardwood plywood, particleboard, and medium density fiberboard composite wood products used on the interior or exterior of the building shall meet the requirements for formaldehyde as specified in Table 5.504.4.			<input checked="" type="checkbox"/>	
A5.504.4.5.1 Early compliance with formaldehyde limits. Where complying composite wood product is readily available for non-residential occupancies, meet Phase 2 requirements before the compliance dates indicated in Table 5.504.4.5 (Tier I), or use composite wood products made with either CARB-approved no-added formaldehyde (NAF) resins or CARB-approved ultra-low emitting formaldehyde (ULEF) resins (Tier II).			<input checked="" type="checkbox"/>	
5.504.4.5.2 Documentation. Verification of compliance with this section shall be provided as requested by the enforcing agency. Documentation shall include at least one of the following.			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
1. Product certifications and specifications.			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
2. Chain of custody certifications.			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
3. Other methods acceptable to the enforcing agency.			<input checked="" type="checkbox"/>	
5.504.4.6 Resilient flooring systems. Comply with the VOC-emission limits defined in the 2009 CHPS criteria and listed on its Low-emitting Materials List (or Product Registry), or certified under the FloorScore program of the Resilient Floor Covering Institute.			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
A5.504.4.6.1 Verification of compliance. Documentation shall be provided verifying that resilient flooring materials meet the pollutant emission limits.			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
DIVISION OF BUILDING AND SAFETY COUNTY OF VENTURA  BUILDING OFFICIAL _____ Jim MacDonald, CBO			B & S STD Revised	B-58 Page 10 - 12 Jan. 2011

ENVIRONMENTAL QUALITY	Method of Compliance	Verification		
		Plan Review	Inspector	Documentation
FIREPLACES				
A5.504.5 Hazardous particulates and chemical pollutants. Minimize and control pollutant entry into buildings and cross-contamination of regularly occupied areas.			<input checked="" type="checkbox"/>	
A5.504.5.2 Isolation of pollutant sources. In rooms where activities produce hazardous fumes or chemicals, exhaust them and isolate them from their adjacent rooms as listed in Items 1 through 3 in A5.504.5.2.			<input checked="" type="checkbox"/>	
5.504.5.3 Filters. In mechanically ventilated buildings, provide regularly occupied areas of the building with air filtration media for outside and return air prior to occupancy that provides at least a MERV of 8.		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
INDOOR MOISTURE AND RADON CONTROL				
5.505.1 Indoor moisture control. Buildings shall meet or exceed the provisions of California Building Code, CCR, Title 24, Part 2, Sections 1203 and Chapter 14.1		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
AIR QUALITY AND EXHAUST				
5.506.1 Outside air delivery. For mechanically or naturally ventilated spaces in buildings, meet the minimum requirements of Section 121 of the California Energy Code, CCR, Title 24, Part 6 and Chapter 4 of CCR, Title 8, or the applicable local code, whichever is more stringent.		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
5.506.2 Carbon dioxide (CO2) monitoring. For buildings equipped with demand control ventilation, CO2 sensors and ventilation controls shall be specified and installed in accordance with the requirements of the latest edition of the California Energy Code, CCR, Title 24, Part 6, Section 121(c).		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
OUTDOOR AIR QUALITY				
5.508.1 Ozone depletion and global warming reductions. Installations of HVAC, refrigeration, and fire suppression equipment shall comply with Sections 5.508.1.1 and 5.508.1.2.			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
5.508.1.1 CFCs. Install HVAC and refrigeration equipment that does not contain CFCs.1		<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	

OUTDOOR AIR QUALITY	Method of Compliance	Plan Review	Verification Inspector	Documentation
5.508.1.2 Halons. Install fire suppression equipment that does not contain Halons.1			<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>