

Ventura County Environmental Health Division 800 South Victoria Avenue, Ventura CA 93009-1730 TELEPHONE: 805/654-2813 or FAX: 805/654-2480

Internet Web Site Address: https://vcrma.org/divisions/environmental-health

CERTIFICATION OF WATER QUALITY

APPLICANT INSTRUCTIONS AND REQUIRED ATTACHMENTS: FOR OFFICE USE ONLY For the item #1 listed below, water quality analysis must be performed at a Statecertified laboratory and water samples must be drawn by laboratory personnel. Received By: _____ Required analyses are shown on Page 2 of this form. Analyses must be less than one Date Received: _____ year old. Provide chain of custody documentation with water analysis documentation. Amount Received: Laboratory analysis or Bacteriological, Primary Inorganic Chemical, Gross Alpha Radiological, and Specific Conductance. (See Page 2 of this application) Receipt Number: _____ A plot plan, drawn to scale, showing the well, waterlines, water tanks, backflow Check Number: devices, structures, septic systems, animal pens, etc. Water well pump and recovery test report approved by Ventura County Public Works Agency, Groundwater Resources Section. PE 6607 A recorded water well agreement if the well is shared between multiple parcels. SR Number: AR Number: Applications are processed in the order received. Allow at least two weeks for processing. Inv. Number: For information on wells, or pump and recovery reports, contact PWA-Groundwater Resources at 805/654-2024. TO BE COMPLETED BY APPLICANT Owner or Authorized Representative: Telephone: _____ Contact Email: Name of Applicant: Mailing Address: _____ State: ____ Zip: ____ Assessor's Parcel # (APN) for building site: State Well Number: Number/type of buildings to be connected, existing + proposed: Number of people served annually by water source: (Only include potable, domestic service connections, such as a residence or office building) For shared water wells: Owner of Water Source: APN: Address: I certify the above information is correct: Signature: Date: FOR OFFICE USE ONLY **Application Approved** Date of Inspection _____ Registered Environmental Health Specialist Approval Date This application, when approved, is valid for two years from the date of approval. There is no guarantee of water quality beyond date of analyses.



Ventura County Environmental Health Division 800 South Victoria Avenue, Ventura CA 93009-1730 TELEPHONE: 805/654-2813 or FAX: 805/654-2480

Internet Web Site Address: https://vcrma.org/divisions/environmental-health

WATER QUALITY STANDARDS

Note: Water quality analysis must be performed at a State-certified laboratory and water samples must be drawn by laboratory personnel. Analyses must be less than one year old. Chain of custody documentation MUST be provided with the original water analysis documentation. Additional testing may be required.

- 1. Bacteriological Quality is measured by the coliform test. The Maximum Contaminant Level (MCL) is <1.0 or "absent". The sample for bacteriological analysis must be drawn after owner's pump is installed in the well.
- 2. Pursuant to California Code of Regulations (CCR), Title 22, Section 64431, the Maximum Contaminant Levels (MCL) for Inorganic Chemicals are:

CHEMICAL	MCL; in mg/l
Aluminum	1.0
Antimony	0.006
Arsenic	0.010
Asbestos	7 *MFL
Barium	1.0
Beryllium	0.004
Cadmium	0.005
Chromium	0.05
Cyanide	0.15
Fluoride	2.0
Mercury	0.002
Nickel	0.1
Nitrate (as Nitrogen)	10.0
Nitrate + Nitrite (sum as nitrogen)	10.0
Nitrite (as nitrogen)	1.0
Perchlorate	0.006
Selenium	0.05
Thallium	0.002

^{*} MFL = Million Fibers per Liter longer than 10 µm

- 3. Pursuant to CCR, Title 22, Section 64442, Radioactivity, the MCL for Gross Alpha is 15 pc/l. Based on these results, additional testing for Uranium, Radium 226 and Radium 228 may be required.
- 4. Pursuant to CCR, Title 22, Section 64449-B, the Secondary Standard for Specific Conductance is 2200 µmhos.

Visit the Ventura County Environmental Health Division Drinking Water webpage for additional information and resources: https://vcrma.org/drinking-water